



Regional Water Testing Laboratory

Address: 4/4 Sanjay Place U.P. JalNigam(Rural) Agra, 282002



TEST REPORT

Report No: UPJN/AGR/26/09/741 Issue Date: 13/09/2026 Page No 1/2

Customer Details

Office Name and Address PRINCIPAL KIDS VANASTHALI PUBLIC SCHOOL KALINDI VIHAR, AGRA

Ref Letter No & Date N/A

Basic details of sample

Block/City	AGRA		
District	AGRA	Village/city	KALINDI VIHAR
Gram Panchayat	-	Location	KIDS VANASTHALI PUBLIC SCHOOL
Water Source	RO WATER	Sample No.	01
Quantity of Sample	1 lt.	Date of Collection	11/09/2026
Receiving Date	11/09/2026	S. Collector	-
Sample Depositor	-	Sampling Method	As per IS 17614: Part 1: 2021
Analysis Start Date	11/08/2026	Analysis Completion Date:	13/09/2026

Technical Data of Analysis

S.No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS, 10500:2012		Ref. Method of Analysis Joint testing(100-130
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH (@ 25°C)	7.50	6-8.5	6.5-8.5	IS 3025 (Part 11):2022 (Electrometric method)
2	Turbidity NTU	0.439	1	5	IS 3025 (Pt 10):1984 (Nephelometric Method)
3	Total Dissolved Solid mg/L	128	500	2000	IS 3025 (Pt 16):1984 (Gravimetric Method)
4	Fluoride mg/L	0.864	1	1.5	APHA 24 rd Edition 4500-F Method C (Electrode method) 2017
5	Total Hardness mg/L	38	200	600	IS 3025 (Part 21):2009(EDTA Method)
6	Total Alkalinity mg/L	52	200	600	IS 3025 (Part 23):1986 (Potentiometric method)
7	Chloride mg/L	24	250	1000	IS 3025 (Part 32):1988 (Argentometric method)
8	Iron mg/L	--	1	1	APHA 24 rd Edition 3500-Fe Method B (Phenanthroline Method) 2017
9	Sulphate mg/L	02	200	400	APHA 24 rd Edition 4500-SO4 Method E (Turbidity Method) 2017
10	Calcium mg/L	22	75	200	IS 3025 (Part 40):1991(EDTA Titrimetric Method)
11	Magnesium mg/L	3.02	30	100	IS 3025 (Part 46):1994(Volumetric Method)



Regional Water Testing Laboratory

Address: 4/4 Sanjay Place U.P. JalNigam(Rural) Agra, 282002



13	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (PART 08) 1984 (Qualitative Method)
14	Nitrate (mg/l)	NIL	45	45	APHA 24 Edition -4500 NO3 method B (UV Spectrophotometric method:2023)

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non-perishable items only) from the date of issue of tests reports.

Amita
(Amita Deyi)
Authorized Signatory:
Testing Lab In charge



Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. UPJN/AGR/26/09/741

Dated: 13/09/2026

It is certified that an inspection team headed by Mr. VIPIN AGARIYA (A.E.) (Name of Officers with designation) from U.P. Jal Nigam (Rural), Agra, inspected the KIDS VANASTHALI PUBLIC SCHOOL, KALINDI VIHAR, AGRA (Name & Address of the school) on 11/09/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no UPJN/AGR/26/09/741 dated 13/09/2026 of Regional Level Water Analysis Laboratory (UP JAL NIGAM) certified that the KIDS VANASTHALI PUBLIC SCHOOL, KALINDI VIHAR, AGRA (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 1 year from issue date

Signature with Seal: सहायक अभियन्ता खण्ड. कार्यालय

Name: Mr. Vipin Agariya उ०प्र० जल निगम (ग्रामीण)

Designation: Assistant Engineer आगरा

Name & Address of the Office / Department:

Regional Level Water Analysis Laboratory

To
KIDS VANASTHALI PUBLIC
SCHOOL, KALINDI VIHAR,
AGRA